

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1501:139 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Edwards, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: David Mazur (203) 699-3155

DESIGN: Models 53DEX, 97DEX and 97DEXC-GW signal lights. Models 53DEX may be followed by B or C; followed by A, B, C, G, M or R; followed by G1 or AW. Models 97DEX may be followed by B or C; followed by A, B, C, G or R; followed by G1.

Units are intended for use in Class I, Groups C and D; Class II, Groups E, F and G; and Class III hazardous areas. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a signal lights for use with separately listed compatible fire alarm control units. Suitable for hazardous location as described under "Design". For indoor use only.

NOTE: Formerly 7300-1388:165

02-27-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 27, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**